

Annexure- C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. UPTN/AGR/26/06/272

Dated: 16/06/2026

It is certified that an inspection team headed by Er. Vipin Agariya / Amrita Devi

(Name of Officers with designation) from U.P.Jal Nigam Agra PHED

inspected the Asian International School Basai, Tundla (Firozabad)

(Name & Address of the school) on 10/06/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. UPTN/AGR/26/06/272 dated 16/06/2026

of Regional water testing laboratory Agra (PHED Lab) certified that

the Asian International School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till one year.

Signature with Seal: सहायक अभियंता

Name : खण्ड कार्यालय

Designation : विपिन अग्रिया

Name & Address of the Office / Department : (A.E.) अग्रिया

To

Principal
Asian International School Basai
(Name & Address of the Institution) Tundla Firozabad

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Regional Water Testing Laboratory

Address: 4/4 Sanjay Place U.P. Jal Nigam (Rural) Agra, 282002



TEST REPORT

Report No:	UPJN/AGR/26/06/272	Issue Date:	16/06/2026	Page No	1
Remark :	-				

Customer Details

Office Name and Address	Asian International School Basai tundla
Ref Letter No & Date	N/A /2026-27 & 10-06-2026

Basic details of sample

		Block/City	Tundla
District	Agra	Village/city	Basai Tundla
Gram Panchayat		Location	Asian International School Basai tundla
Water Source	R.O.Water	Sample No.	01
Quantity of Sample	1 Lt.	Date of Collection	10/06/2026
Receiving Date	10/06/2026	S. Collector	Mr.
Sample Depositor	Mr.	Sampling Method	As per IS 17614: Part 1: 2021
Analysis Start Date	12/05/2026	Analysis Completion Date:	13/05/2026

Technical Data of Analysis

S. No.	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS, 10500:2012		Ref. Method of Analysis Joint testing(100-130)
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH (@ 25°C)	7.46	6-8.5	6.5-8.5	IS 3025 (Part 11):2022(Electrometric method)
2	Turbidity NTU	0.98	1	5	IS 3025 (Part 10):2023 (Nephelometric Method)
3	Total Dissolved Solid mg/L	160	500	2000	IS 3025 (Pt 16):2023 (Gravimetric Method)
4	Fluoride mg/L	-	1	1.5	APHA 24 th Edition 4500-F Method C (Electrode method) 2023
5	Total Hardness mg/L	22	200	600	IS 3025 (Part 21):2023(EDTA Method)
6	Total Alkalinity mg/L	48	200	600	IS 3025 (Part 23):1986 (Potentiometric method)
7	Chloride mg/L	36	250	1000	IS 3025 (Part 32):2025 (Argentometric method)
8	Iron mg/L	--	1	1	APHA 24 th Edition 3500-Fe Method B (Phenanthroline Method) 2023
9	Sulphate mg/L	NIL	200	400	APHA 24 th Edition 4500-SO4 Method E (Turbidity Method) 2023
10	Calcium mg/L	12	175	200	IS 3025 (Part 40):2024(EDTA Titrimetric Method)
11	Magnesium mg/L	4.32	30	100	IS 3025 (Part 46):2023(Volumetric Method)
12	Color (Hazen)	1	5	15	IS3025 Edition(Part 4) Color (Visual Comparison Method)
13	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (PART 08) 2023 (Qualitative Method)
14	Nitrate (mg/l)	NIL	45	45	APHA 24 Edition -4500 NO3 method B (UV Spectrophotometric method:2023)

Note:

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non-perishable items only) from the date of issue of tests

Prepared by

(Amita Deva)
Authorized Signatory
Testing Lab In charge
QUALITY
MANAGER

Laboratory Contact details
Mob. (8630905287)

End of Report